

ICC-ES Evaluation Report

ESR-2600

Reissued February 1, 2011

This report is subject to re-examination in two years.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

**DIVISION: 07 00 00—THERMAL AND MOISTURE
PROTECTION**
Section: 07 21 00—Thermal Insulation
REPORT HOLDER:

DEMILEC USA LLC
 2925 GALLERIA DRIVE
 ARLINGTON, TEXAS 76011
 (817) 640-4900
www.demilecusa.com

EVALUATION SUBJECT:
**SEALECTION AGRIBALANCE® SPRAY FOAM
INSULATION**

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2009 *International Building Code*® (IBC)
- 2009 *International Residential Code*® (IRC)
- 2009 *International Energy Conservation Code*® (IECC)
- Other Codes (see Section 8.0)

Properties evaluated:

- Surface-burning characteristics
- Physical properties
- Thermal resistance
- Attic and crawl space installation
- Air permeability

2.0 USES

Sealection Agribalance® spray foam insulation is used as a nonstructural thermal insulating material in Type V-B construction under the IBC and dwellings under the IRC. The insulation is for use in wall cavities, floor assemblies, roof/ceiling assemblies or attics and crawl spaces when installed in accordance with Section 4.4. Under the IRC, the insulation may be used as air-impermeable insulation when installed in accordance with Section 3.4.

3.0 DESCRIPTION

3.1 General:

Sealection Agribalance® is a spray-applied, semirigid, low-density, cellular polyurethane foam plastic that is installed as a nonstructural component of floor/ceiling and wall assemblies. The material is a two-component, open-cell spray-applied polyurethane foam plastic system. The

product is a water-blown foam with nominal density of 0.7 pcf (11.2 kg/m³) and installed density of 0.6-0.8 pcf (9.6 - 12.8 kg/m³). The polyurethane foam is produced in the field by combining a polymeric isocyanate (component A) and a resin (component B). The products have a shelf life of one year, when stored in factory-sealed containers at temperatures between 40°F and 100°F (4.5°C and 38°C).

Sealection Agribalance® spray foam insulation is an air-impermeable insulation in accordance with Section R806.4 of the IRC, based on testing in accordance with ASTM E 283.

3.2 Surface-burning Characteristics:

The insulation at a maximum thickness of 5.5 inches (139.7 mm) and a density of 0.6 pcf (9.6 kg/m³), has a flame-spread index of less than 25 and smoke-developed index of less than 450 when tested in accordance with ASTM E 84. Thicknesses up to 9¹/₄ inches (235 mm) for wall cavities and 14 inches (356 mm) for floor/ceiling cavities are recognized, based on room corner fire testing in accordance with NFPA 286, when covered with minimum 1/2-inch-thick (12.7 mm) gypsum wallboard or an equivalent 15-minute thermal barrier complying with, and installed in accordance with, IBC Section 2603.4 or IRC Section R316.4, as applicable.

3.3 Thermal Resistance, R-values:

The insulation has thermal resistance, R-values, at a mean temperature of 75°F (24°C), as shown in Table 1. Heatlok® Soy 200 has a thermal resistance R-value, at a mean temperature of 75°F (24°C), of 7.4 per inch.

3.4 Air Permeability:

Sealection Agribalance® spray-applied polyurethane foam insulation, at a minimum of 3.5 inches (89 mm), is considered air-impermeable insulation in accordance with Section R806.4 of the IRC based on testing in accordance with ASTM E 283 and ASTM E 2178.

3.5 Blazelok™ IB4 Intumescent Coating:

Blazelok™ IB4 intumescent coating, manufactured by TPR² Corporation, is a one-component, water-based liquid coating with specific gravity of 1.3. Blazelok™ IB4 is supplied in 5-gallon (19 L) pails and/or 55-gallon (208 L) drums and has a shelf life of one year when stored in factory-sealed containers at temperatures between 45°F (7°C) and 90°F (32°C).

3.6 No-Burn® Plus XD Intumescent Coating:

No-Burn® Plus XD intumescent coating, manufactured by No-Burn, Inc., is a translucent aqueous liquid in 1- and 5- gallon (3.8 and 18.8 L) pails and 55-gallon (208 L)

drums. The coating has a shelf life of three years when stored in a factory-sealed container at temperatures between 40°F (4.5°C) and 90°F (32°C).

3.7 Heatlok Soy® 200 Coating:

Heatlok® Soy 200, manufactured by Demilec USA LLC, is a spray-applied foam used as a coating over the Sealection Agribalance® foam insulation, as described in Section 4.4.2.4. The Heatlok® Soy 200 coating is a two-component, closed-cell polyurethane foam plastic insulation with a density of 2.1 pcf (34 kg/m³) that is installed as a nonstructural component in walls and floor/ceiling assemblies. The foam plastic components have a shelf life of one year when stored in factory-sealed containers at temperatures between 59°F and 77°F (15°C and 25°C). The foam coating has a thermal resistance, *R*-value, of 7.4 per inch, to a maximum of 2 inches (51 mm), at a mean temperature of 75°F (24°C); and qualifies as Class II vapor retarder under the IRC when applied at a minimum thickness of 1.2 inches (30.5 mm).

3.8 Sustainable Attributes:

See ICC-ES [VAR-1006](#) for determination of biobased content.

4.0 DESIGN AND INSTALLATION

4.1 General:

Sealection Agribalance® spray foam insulation must be installed in accordance with the manufacturer's published installation instructions and this report. A copy of the manufacturer's published installation instructions must be available at all times on the jobsite during installation.

4.2 Application:

The insulation is spray-applied on the jobsite using a volumetric positive displacement pump as identified in the Demilec application manual. The insulation can be installed in one pass to the maximum thickness as specified in Sections 3.2 and 4.4.2. The foam plastic must not be used in electrical outlet or junction boxes or in contact with rain, water, or soil. The foam plastic must not be sprayed onto a substrate that is wet, or covered with frost or ice, loose scales, rust, oil, or grease. Sealection Agribalance® resin (component B) must be stored in areas where the ambient temperature is between 40°F and 100°F (4.5°C and 38°C). Sealection Agribalance® must be used in areas where maximum ambient temperature is equal or less than 180°F (82°C). The insulation must be protected from the weather during and after application.

4.3 Thermal Barrier:

Sealection Agribalance® spray foam insulation must be separated from the interior of the building by an approved thermal barrier of 1/2-inch-thick (12.7 mm) gypsum wallboard or an equivalent 15-minute thermal barrier complying with, and installed in accordance with, IBC Section 2603.4 or IRC Section R316.4, as applicable, except when installation is in attics and crawl spaces, as described in Section 4.4. Thicknesses of up to 9 1/4 inches (235 mm) for wall cavities and 14 inches (356 mm) for floor/ceiling cavities are recognized, based on room corner fire testing in accordance with NFPA 286.

4.4 Attics and Crawl Spaces:

4.4.1 Application with a Prescriptive Ignition Barrier:

When Sealection Agribalance® insulation is installed within attics or crawl spaces where entry is made only for service of utilities, an ignition barrier must be installed in accordance with IBC Section 2603.4.1.6 or IRC Sections R316.5.3 and R316.5.4, as applicable. The ignition barrier

must be consistent with the requirements for the type of construction required by the applicable code, and must be installed in a manner so the foam plastic insulation is not exposed. Sealection Agribalance® insulation as described in this section may be installed in unvented attics in accordance with IRC Section R806.4.

4.4.2 Application without a Prescriptive Ignition Barrier:

4.4.2.1 General: Where Sealection Agribalance® insulation is installed without a prescriptive ignition barrier in attics and crawl spaces in accordance with Sections 4.4.2 and 4.4.3, the following conditions apply:

- Entry to the attic or crawl space is only to service utilities and no storage is permitted.
- There are no interconnected attic or crawl space areas.
- Air in the attic or crawl space is not circulated to other parts of the building.
- Attic ventilation must be provided when required by the applicable code, except when air-impermeable insulation is permitted in unvented attics in accordance with Section R806.4 of the IRC.
- Under-floor (crawl space) ventilation is provided when required by IBC Section 1203.3 or IRC Section R408.1, as applicable.
- Combustion air must be provided in accordance with *International Mechanical Code*® (IMC) Section 701.

4.4.2.2 Application with Blazelok™ IB4 Coating: In attics, Sealection Agribalance® insulation may be spray-applied to the underside of roof sheathing and/or rafters; and the underside of wood floors and/or floor joists in crawl spaces as described in this section. The thickness of the foam plastic applied to the underside of the wood floor and roof sheathing must not exceed 1 1/4 inches (285.8 mm). The spray foam insulation applied to vertical wall surfaces in attics and crawl spaces must not exceed 9 1/4 inches (235 mm) in depth. The foam plastic surface must be covered with a minimum 5-dry-mil [9 wet mils (0.23 mm)] thickness of Blazelok™ IB4 intumescent coating as described in Section 3.5. The intumescent coating must be spray-applied over the insulation in accordance with the coating manufacturer's instructions and this report at a rate of 1 gallon (3.38 L) per 175 square feet (16.3 m²) to obtain the recommended minimum dry film thickness noted in this section. Surfaces to be coated must be dry and clean, and free of dirt, loose debris and any other substances that could interfere with adhesion of the coating.

4.4.2.3 Application with No-Burn® Plus XD Intumescent Coating:

In attics, Sealection Agribalance® foam insulation may be spray-applied to the underside of the roof sheathing and/or rafters and in crawl spaces. The insulation may be spray-applied to the underside of wood floors as described in this section. The thickness of the foam plastic applied to the underside of the top of the space must not exceed 1 1/2 inches (292 mm), and the thickness on vertical surfaces must not exceed 9 1/2 inches (241 mm). The foam plastic surface must be covered with a minimum nominal thickness of 6 dry mils (0.15 mm) [10 wet mils (0.25 mm)] of the No-Burn® Plus XD intumescent coating described in Section 3.6. The intumescent coating must be spray-applied over the insulation in accordance with the coating manufacturer's instructions and this report at a rate of 1 gallon (3.38 L) per 160 square feet (14.9 m²) to obtain the recommended minimum dry film thickness noted in this section. Surfaces to be coated must be dry and clean, and free of dirt, loose debris and any other substances that could interfere with adhesion of the coating.

4.4.2.4 Application of Sealection Agribalance® with Heatlok Soy® 200 Coating: Sealection Agribalance® foam insulation may be spray-applied to the underside of roof sheathing and/or rafters; and the underside of wood floors and/or floor joists in crawl spaces as described in this section. The thickness of the foam plastic applied to the underside of the wood floor and roof sheathing must not exceed 9¹/₂ inches (241 mm). The spray foam insulation applied to vertical wall surfaces in attics or crawl spaces must not exceed 5¹/₂ inches (140 mm) in depth. Sealection Agribalance® foam insulation applied to all surfaces must be covered with a nominal thickness of 2 inches (51 mm) of Heatlok Soy® 200 spray foam coating as described in Section 3.7.

4.4.3 Use on Attic Floors: Sealection Agribalance® spray-applied insulation may be installed exposed at a maximum thickness of 9¹/₂ inches (241 mm) between and over the joists in attic floors, when covered with the No-Burn® Plus XD intumescent coating described in Section 4.4.2.3. Sealection Agribalance® spray-applied insulation may be installed exposed at a maximum thickness of 9¹/₄ inches (235 mm) between and over the joists in attic floors, when covered with the Blazelok™ IB4 intumescent coating described in Section 4.4.2.2. The foam plastic insulation may be installed at a maximum of 5¹/₂ inches (140 mm) between and over the joists in an attic floor when covered with a nominal 2 inches (51 mm) of Heatlok Soy® 200 coating as described in Section 4.4.2.4. The insulation must be separated from the interior of the building by an approved thermal barrier. The ignition barrier in accordance with IBC Section 2603.4 and IRC Section R316.5.3 may be omitted.

5.0 CONDITIONS OF USE

The Sealection Agribalance® spray-applied foam insulation described in this report complies with, or is a suitable alternative to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 This evaluation report and the manufacturer's published installation instructions, when required by the code official, must be submitted at the time of permit application.
- 5.2 The products must be installed in accordance with the manufacturer's published installation instructions, this evaluation report and the applicable code. The instructions within this report govern if there are any conflicts between the manufacturers' published installation instructions and this report.
- 5.3 The insulation must be separated from the interior of the building by an approved 15-minute thermal barrier, except when installation is in attics and crawl spaces as described in Section 4.4.
- 5.4 The insulation must not exceed the density and thicknesses noted in Sections 3.2, 4.4.2 and 4.4.3 of this report.
- 5.5 The insulation must be protected from the weather during and after application.
- 5.6 The insulation must be applied by contractors certified by Demilec USA.
- 5.7 Use of the insulation in areas where the probability of termite infestation is "very heavy" must be in accordance with IRC Section R318.4 or IBC Section 2603.8, as applicable.

5.8 The insulation has been evaluated only for use in Type V-B construction under the IBC and non-fire-resistance rated assemblies in dwellings under the IRC.

5.9 Jobsite certification and labeling of the insulation must comply with IRC Sections N1101.4 and N1104.4.1 and IECC Sections 303.1.1 and 303.1.2, as applicable.

5.10 A vapor retarder must be installed when required by the applicable code.

5.11 The insulation is produced in Arlington, Texas, under a quality control program with inspections by Intertek Testing Services NA Ltd. (AA-647).

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with ICC-ES Acceptance Criteria for Spray-applied Foam Plastic Insulation (AC377), dated October 2010, including testing in accordance with Appendix X.
- 6.2 Reports of room corner fire tests in accordance with NFPA 286.
- 6.3 Reports of air leakage tests in accordance with ASTM E 283.
- 6.4 Reports of air permeance tests in accordance with ASTM E 2178.

7.0 IDENTIFICATION

Components of Sealection Agribalance® spray foam insulation are identified with the manufacturer's name (Demilec USA), address and telephone number; the product trade name (Sealection Agribalance®); use instructions; the density; the flame-spread and smoke-development indices; the evaluation report number (ESR-2600); and the name of the inspection agency (Intertek Testing Services NA Ltd.)

Each pail of Blazelok™ IB4 intumescent coating is labeled with the manufacturer's name (TPR² Corporation), the product name and use instructions.

No-Burn® Plus XD intumescent coating is identified with the manufacturer's name (No-Burn, Inc) and address, the product trade name, and use instructions.

Heatlok® Soy 200 coating is identified with the manufacturer's name (Demilec USA), address and telephone number, the product trade name and use instructions.

8.0 OTHER CODES

In addition to the codes referenced in Section 1.0, the products described in this report have been evaluated in accordance with the following codes:

- 2006 *International Building Code*® (2006 IBC)
- 2006 *International Residential Code*® (2006 IRC)
- 2006 *International Energy Conservation Code*® (2006 IECC)
- 2003 *International Building Code*® (2003 IBC)
- 2003 *International Residential Code*® (2003 IRC)
- 2003 *International Energy Conservation Code*® (2003 IECC)

The products comply with the above-mentioned codes as described in Sections 2.0 through 7.0 of this report, with the revisions noted below:

- **Application with a Prescriptive Thermal Barrier:** See Section 4.3, except the approved thermal barrier must be installed in accordance with Section R314.4 of the 2006 IRC or Section R314.1.12 of the 2003 IRC.
- **Application with a Prescriptive Ignition Barrier:** See Section 4.4.1, except attics must be vented in accordance with Section 1203.2 of the 2006 and 2003 IRC or Section R806 of the 2003 IRC, and crawl space ventilation must be in accordance with Section 1203.3 of the 2006 and 2003 IRC or Section R408 of the 2006 and 2003 IRC, as applicable. Additionally, an ignition barrier must be installed in accordance with Section R314.5.3 or R314.5.3 of the 2006 IRC or Section R314.2.3 of the 2003 IRC, as applicable.
- **Application without a Prescriptive Ignition Barrier:** See Section 4.4.2, except attics must be vented in accordance with Section 1203.2 of the 2006 and 2003 IRC or Section R806 of the 2006 and 2003 IRC, and crawl space ventilation must be in accordance with Section 1203.3 of the 2006 and 2003 IRC, as applicable.
- **Protection Against Termites:** See Section 5.7, except use of the insulation in areas where the probability of termite infestation is “very heavy” must be in accordance with Section R320.5 of the 2006 IRC or Section R320.4 of the 2003 IRC.
- **Jobsite Certification and Labeling:** See Section 5.9, except jobsite certification and labeling must comply with Sections 102.1.1 and 102.1.11, as applicable, of the 2006 IECC.

TABLE 1—THERMAL RESISTANCE (R-VALUES)

THICKNESS (INCH)	R-VALUE ¹ (°F.ft ² .h/Btu)
1	4.5
2	8.9
3	13.4
3.5	15.6
4	17.8
5.5	24.5
6	26.7
7.5	33.4
9.25	41.2
9.5	42.3
10	44.5
11.25	50.1
11.5	51.1
14	62.3

For SI: 1 inch = 25.4 mm; 1°F.ft².h/Btu = 0.176 110°K.m²/W.

¹R-values are calculated based on tested K-values at 1-and 4-inch thicknesses.

ICC-ES SAVE: Verification of Attributes Report™
VAR-1006

Issued September 1, 2009

This report is subject to re-examination in one year.

www.icc-es.org/save | 1-800-423-6587 | (562) 699-0543 A Subsidiary of the International Code Council®

DIVISION: 07—THERMAL AND MOISTURE PROTECTION
Section: 07 21 16—Building Insulation
Section: 07210—Building Insulation
REPORT HOLDER:
DEMILEC (USA) LLC
 2925 GALLERIA DRIVE
 ARLINGTON, TEXAS 76011
 (817) 640-4900

www.demilecusa.com
info@demilecusa.com
EVALUATION SUBJECT:
SEALECTION AGRIBALANCE™
1.0 EVALUATION SCOPE
Compliance with the following evaluation guideline:

ICC-ES Evaluation Guideline for Determination of Biobased Material Content (EG102), dated October 2008.

2.0 USES

SEALECTION Agribalance™ is a semirigid, low-density, cellular polyurethane foam plastic insulation that is spray-applied as a nonstructural insulating component of floor/ceiling and wall assemblies.

3.0 DESCRIPTION

 SEALECTION Agribalance™ is a two-component system with a density ranging from 0.60 to 0.80 lb/ft³ (9.60 and 12.80 kg/m³). The polyurethane is produced by combining the two components on-site. Water is used as the blowing agent and reacts with the isocyanate, which releases carbon dioxide and steam, causing the mixture to expand. The mixture is spray-applied to the surfaces intended to be insulated.

The insulation contains a minimum percentage of biobased content as noted in Table 1.

4.0 CONDITIONS

 See ICC-ES evaluation report [ESR-2600](#) for compliance of SEALECTION Agribalance™ with code requirements.

5.0 IDENTIFICATION

The SEALECTION Agribalance™ spray foam insulation described in this report is identified by a stamp bearing the manufacturer's name [Demilec (USA) LLC] and address, the product name (SEALECTION Agribalance), and the VAR number (VAR-1006).

TABLE 1—BIOBASED MATERIAL CONTENT SUMMARY

% MEAN BIOBASED CONTENT	METHOD OF DETERMINATION
10% (+/- 3%) ¹	ASTM D 6886

¹Based on precision and bias cited in ASTM D 6886.